



Wels, July 03rd 2017

CONFORMITY VDE-AR-N-4105 FRONIUS INVERTERS

Fronius International GmbH

hereby confirms that the Fronius inverters

- / **Fronius Primo 3.0-1 – 8.2-1**
- / **Fronius Galvo 1.5-1 – 3.1-1**
- / **Fronius Symo 3.0-3-M – 20.3-3-M**
- / **Fronius Symo Hybrid 3.0-3-S – 5.0-3-S**
- / **Fronius Eco 25.0 – 27.0**

meet the requirements according to the German low voltage directive VDE-AR-N 4105 when set to Setup DE1, DE2 or DE3. This is tested and certified by the German test- and certification body VDE and recorded by the corresponding certificates.

Fronius International GmbH

Business Unit Solar Energy
Froniusplatz 1
A-4600 Wels

A handwritten signature in blue ink, appearing to read "Thomas Mühlberger".

DI Thomas Mühlberger
Head of Solution Management